

# Copy of Water Examination Report issued by Medical Officer, Primary Health Center, Gandhinagar



## PRIMARY HEALTH CENTRE

UNAVA - 382650 Dist. Gandhinagar

### SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 12.06.2025


It is certified that an inspection team headed by DR. BINABEN PATEL, MEDICAL OFFICER from PRIMARY HEALTH CENTER, UNAVA - DIST.GANDHINAGAR inspected the GREEN VALLEY SCHOOL FOR CHILDREN run by SMT. H. M DEDANIA CHARITABLE TRUST situated at LEKAWADA - DHARAMPUR ROAD, AT & POST : LEKAWADA, TALUKA AND DIST. : GANDHINAGAR - 382024 on 12.06.2025 and on the basis of Water Test Report (attached) bearing no 415/2025-26 dated 10.06.2025 of DISTRICT LABORATORY, GANDHINAGAR certified that the GREEN VALLEY SCHOOL FOR CHILDREN has safe drinking water facilities for the students and members of staff of the Institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till FIVE YEARS.

Signature with Seal


Name:

Designation:

Name & Address of the  
Office / Department:





  
DR. BINABEN PATEL  
MEDICAL OFFICER  
PRIMARY HEALTH CENTER,  
UNAVA, GANDHINAGAR  
MEDICAL OFFICER  
PHC :- UNAVA  
TA. DIST. GANDHINAGAR

To,  
Manager,  
Green Valley School For Children,  
Gandhinagar

  
Principal  
Green Valley School for Children  
Gandhinagar

  
Managing Director  
Green Valley School for Children  
Gandhinagar

# Copy of Water Examination Report issued by District Laboratory, Gandhinagar





 <b>GUJARAT WATER SUPPLY &amp; SEWERAGE BOARD</b> <b>DISTRICT LABORATORY GANDHINAGAR</b> Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar		DL/7.8/F-01  TC-12024		
<b>Test Report</b>				
<b>Name &amp; Address of Customer:-</b> Green Valley School For Children Lekawada Dahegam Gandhinagar				
<b>Customer Reference No.:-</b> Sample Submitted by :Customer Date of Sample Receipt :06-Jun-2025 Analysis Starting Date :09-Jun-2025 Analysis Completion Date :09-Jun-2025 Discipline:Chemical Testing,Group:Drinking Water ULR - TC129242500000415F				
Test Report No.: 415/2025-26		Date of Issue : 10-Jun-2025		
Sample ID : 415		Mode of Sample: Satisfactory		
Main Source :Ground Water		Source :R.O. Water		
Location :Green Valley School For Children				
Village :Lekawada		Habitation :Lekawada		
Taluka :Dahegam		District :Gandhinagar		
Latitude :-		Longitude :-		
Kindly find herewith the Analytical Results.		Sample Type : Drinking Water		
Sr.No.	Parameter	Unit	Reference Method :	Analytical Value
1	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
2	Turbidity	NTU	APHA (24 th Ed.2023), Method: 2130 B	1.26
3	pH at 25°C	-	APHA (24 th Ed.2023) Method: 4500 H <sup>+</sup> B	7.74
4	Conductivity at 25°C	μS/cm	APHA (24 th Ed.2023) Method: 2510 B	1100
5	Total Dissolved Solids	mg/l	APHA (24 th Ed.2023) Method: 2540 C	704
6	Total Hardness(as CaCO <sub>3</sub> )	mg/l	APHA (24 th Ed.2023) Method: 2340 C	216
7	Calcium (as Ca <sup>+2</sup> )	mg/l	APHA (24 th Ed.2023) Method: 3500 Ca+2 B	42
8	Magnessium (as Mg <sup>+2</sup> )	mg/l	APHA (24 th Ed.2023) Method: 3500-Mg+2 B	27
9	Chloride (as Cl <sup>-</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-Cl - B	240
10	Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-SO4-2 E	52
11	Nitrate (as NO <sub>3</sub> <sup>-</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-NO3- B	21.72
12	Fluoride (as F <sup>-</sup> )	mg/l	APHA (24 th Ed.2023) Method: 4500-F - C	0.41
13	Total Alkalinity(as CaCO <sub>3</sub> )	mg/l	APHA (24 th Ed.2023) Method: 2320 B	268
<b>This Report is issued under the following terms &amp; Condition :</b> 1. This report is referring only to the tested sample and for applicable parameter. 2. The sample will be destroyed after retention time unless otherwise specified specially. 3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law. 4. Please refer back page for IS 10500:2012 (2 <sup>nd</sup> Revision) limits.				
		Issued By:  <b>Khyati Nayak</b> (Quality Manager) Authorized Signatory		
----- End of the Test Report ----- O.W.No. DL/GNR/ 415 of 2025, Dt. 10.6.2025. Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar E-mail: districtlabgandhinagar@gmail.com				

  
**Principal**  
 Green Valley School for Children  
 Gandhinagar

  
**Managing Director**  
 Green Valley School for Children  
 Gandhinagar



# Copy of Bacteriological Examination Report issued by District Laboratory, Gandhinagar

	<b>DISTRICT LABORATORY</b> <b>GUJARAT JALSEVA TRAINING INSTITUTE</b> <b>GUJARAT WATER SUPPLY &amp; SEWERAGE BOARD</b> <b>SECTOR - 15, 'G' Road, GANDHINAGAR - 382016</b>	
<b>REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER</b>		
<b>Name &amp; Address:-</b>		
Green Valley School For Children	Sender's Ref.No:	-
Lekawada, Dahegam	Date of Receipt at Lab. / Arrival Date:	6-Jun-25
Gandhinagar	Sample Collected By:	Sender
Lab Ref. i.e. BW No.	360	
Date of Collection	6-Jun-25	
Date of Commencing Examination:	6-Jun-25	
Source of Water Sample	Bore Water	
	Green Valley School For Children	
Village	Lekawada	
Habitation	Lekawada	
Taluka	Dahegam	
District	Gandhinagar	
Membrane Filtration Method, IS-15185:2016, ISO 9308-1:2014 for Total Coliform	< 1	
Membrane Filtration Method, IS-15185:2016, ISO 9308-1:2014 for Therotolerant Fecal Coliform ( <i>E.coli</i> )	< 1	
Opinion For Potability As Per The BIS:10500:2012	Safe	
<b>Important Note:-</b>		
*Sample should be collected in sterile BOD bottle.		
**"Unsafe" :- Proper Disinfection may render it safe.		
*Presence of Coliform in water sample indicates the need of proper Disinfection.		
<b>NOTE :</b>		
Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Revision.		
*All Water Intended for Drinking -		
(a) <i>E.coli</i> or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.		
*Treated Water Entering the Distribution system & Treated Water in the Distribution system -		
(a) <i>E.coli</i> or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.		
(b) Total coliform bacteria shall not be detectable in any 100ml sample.		
1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.		
2) This Report should not be taken as a basis to getting license from any Government authority.		
3) After Collection of Bacteriological sample, it must be preserved at (5±3)°C and submitted to laboratory within 24hrs.		
Analysed By:  Microbiologist	 Lab Incharge	
Outward No.: GJTI/Dist.Lab/BWT <u>360</u> / of 2025, Date: <u>11/6</u> /2025		

  
**Principal**  
**Green Valley School for Children**  
**Gandhinagar**

  
**Managing Director**  
**Green Valley School for Children**  
**Gandhinagar**